

## **SECTION 8**

### **8.18 FIRELINE CONNECTIONS:**

The installation of fire line connections shall conform to Sheet 34 of the Standard Drawings and to the appropriate sections of Chapter 3, SERVICE LINES AND APPURTENANCES. Fire line connections shall be restrained, ductile iron pipe only. The fire line connection shall have a valve 2 feet from the property line on the street side of the property line. The fire line connection shall be protected from corrosion.

Fire line connections for residential usage only are available in one inch and 2 inch sizes if approved by Denver Water. Requests for these connections must be submitted with drawings to Denver Water for approval.